

EU RO Mutual Recognition Technical Requirements

CONTACTORS WITH ELECTRONIC DEVICES	Version	0.2
	Adoption Date	1 July 2018
	Application Date	1 January 2019
	Tier	4
This document is subject to controlled issue and can be found here: http://www.euomr.org/technical-requirements *** Uncontrolled if downloaded or printed ***		

1. PRODUCT DESCRIPTION	1
2. DESIGN EVALUATION	2
3. PRODUCTION REQUIREMENTS	4
4. MARKING REQUIREMENTS	4
5. TYPE APPROVAL CERTIFICATE CONTENT	4
6. APPROVAL DATE AND REVISION NUMBER	5
7. BACKGROUND INFORMATION / REFERENCES	5
8. MAINTENANCE / CLARIFICATION OF TECHNICAL REQUIREMENTS	6

1. PRODUCT DESCRIPTION

1.a General description of the product

The description of the product is used according to IEC IEV 441-14-33.

Contact: A mechanical switching device having only one position of rest, operated other than by hand, capable of making, carrying and breaking currents under normal circuit conditions including operating overload conditions.

1.b Application limitations†

- Restricted to LV electromechanical contactors according to IEC 60947-4-1 where the rated voltage does not exceed 1000V a.c. or 1500V d.c.;
- On board ships with exceptions as per SOLAS Ch. I, Reg. 3;
- Installation on board ships within locations with climatic, biological, chemically active, mechanically active and mechanical environmental conditions not exceeding those for which performance has been proved according to IEC 60721-3-6 (1987) + A2 (1997).

† The EU MR type approved product is generally not used as a stand-alone product, but integrated as component in a sub-system or system. When a product is presented with an EU RO MR Type Approval Certificate for given application, its acceptability with regards to conditions defined in 1b, 1c and 1d of this Technical Requirement will be evaluated by the EU RO in charge of classing the ship or being in charge of the unit/system certification.

EU RO Mutual Recognition Technical Requirements

CONTACTORS WITH ELECTRONIC DEVICES	Version	0.2
	Adoption Date	1 July 2018
	Application Date	1 January 2019
	Tier	4
This document is subject to controlled issue and can be found here: http://www.euromr.org/technical-requirements *** Uncontrolled if downloaded or printed ***		

1.c Intended use

- a) Power supply system characteristics as per IEC 60092-101, 2.8;
- b) For equipment tested according to their respective environmental categories I-IV see **7. Background information/ References**).

1.d System context

See 1.c.

2. DESIGN EVALUATION

2.a Engineering evaluation requirements

2.a i. Technical Requirements

- a) Type, ratings and characteristics of contactors for intended applications shall be evaluated;
- b) In general, the IEC 60947 series applies.

2.a.ii. Technical documents to be submitted

Prior to tests:

- a) Proposed test program and test schedule;
- b) Description of the test specimens and explanation of the selected test sample(s) providing evidence that the selected sample meets the most rigorous and demanding requirements.;
- c) Product descriptions, manuals, data sheets, assembly drawings, dimension drawings, etc., clearly identifying the product;
- d) Complete accreditation certificate of the Test laboratory (prior to the first test only; changes in the scope of accreditation shall also be advised);
- e) Details of production sites;
- f) Product specification;
- g) Application, working area;
- h) Instructions on fitting, assembly and operation;
- i) QM-certificate according to ISO 9001.

EU RO Mutual Recognition Technical Requirements

CONTACTORS WITH ELECTRONIC DEVICES	Version	0.2
	Adoption Date	1 July 2018
	Application Date	1 January 2019
	Tier	4
This document is subject to controlled issue and can be found here: http://www.euomr.org/technical-requirements *** Uncontrolled if downloaded or printed ***		

After completion of tests:

- j) The test report with an identification number shall contain all relevant data and test results including place and date of the tests, the names of the responsible personnel carrying out the test;
- k) Type references and serial numbers of the products tested;
- l) Test reports and test records shall be signed by the personnel members in charge of the test and are to be confirmed by the EU RO through the signing and marking of the test report.

2.b Type testing requirements

- a) In general, the type test plan is to be agreed between the Manufacturer and the RO based on the characteristics of the product subject to testing;
- b) The type tests are intended to demonstrate the performance of the prototype according to the requirements of the applicable International Standards and the relevant Manufacturer's specification;
- c) The ability of the product to function as intended under the testing conditions specified in the latest revision of IACS UR E10 shall also be verified. Testing procedures according to the International Standards mentioned in this TR may be accepted by the RO, in lieu of those indicated in the IACS UR E10, provided that the test severity conditions set by the IACS UR E10 are fulfilled as a minimum;
- d) Performance type tests according to the Manufacturer's specification and the applicable International Standards shall be carried out;
- e) Environmental tests should be carried out in accordance with last revision of IACS UR E10 (applicable items) or in accordance with IEC 60947-4-1 sub-clause 9.1.5.2 and IEC 60947-1 Annex Q - Category D, with the severity conditions set by the IACS UR E10 as a minimum, notably for the resulting recovery times;
- f) Electromagnetic compatibility (EMC) to be tested in accordance with the procedures indicated in the IACS UR E10 or in accordance with IEC 60947-4-1 sub-clause 8.3, with the severity conditions set by the IACS UR E10 as a minimum;
- g) All tests to be performed on agreed test samples. Test specimens shall be selected from production line or at random from stocks†;
- h) Tests shall be carried out in the presence of the EU RO Surveyor. In cases where the tests are conducted at Nationally Accredited Laboratories, the presence of the EU RO surveyor may be omitted†.

EU RO Mutual Recognition Technical Requirements

CONTACTORS WITH ELECTRONIC DEVICES	Version	0.2
	Adoption Date	1 July 2018
	Application Date	1 January 2019
	Tier	4
This document is subject to controlled issue and can be found here: http://www.euomr.org/technical-requirements *** Uncontrolled if downloaded or printed ***		

† For further clarification of witnessing of tests and sampling the test specimen(s), refer to paragraphs 6, 7 and 8 of the EU RO “Design Evaluation Scheme” procedure (Appendix V of EU RO Framework Document for the Mutual Recognition of Type Approval found on <https://www.euomr.org/technical-requirements>).

3. PRODUCTION REQUIREMENTS

3.a. General Requirements

Refer to EU RO “Product Quality Assurance (PQA)” procedure (Appendix VI of EU RO Framework Document for the Mutual Recognition of Type Approval).

3.b. Special Requirements

- a) Routine test according to IEC 60947-4-1 sub-clause 9.1.3;
- b) Production certification according to ISO 9001 by accredited certification bodies;
- c) QM/QS audit (annual) shall be submitted to the EU RO for review;
- d) Production of the equipment is limited to those facilities listed on EU RO’s certificate;
- e) Changes to the product, or its embedded software (firmware), will void the EU RO’s certification;
- f) The EU RO shall be granted access to all manufacturing and testing facilities, and to be provided with all the information necessary to perform its duties;
- g) General terms and conditions of EU RO shall be observed.

4. MARKING REQUIREMENTS

Marking as required by IEC 60947-4-1 (sub-clause 6.2).

5. TYPE APPROVAL CERTIFICATE CONTENT

The EU RO MR Type Approval Certificate shall contain the minimum information as defined in the “EU RO Framework Document for the Mutual Recognition of Type Approval” - see Appendix I EU RO MR Type Approval Certificate Information.

EU RO Mutual Recognition Technical Requirements

CONTACTORS WITH ELECTRONIC DEVICES	Version	0.2
	Adoption Date	1 July 2018
	Application Date	1 January 2019
	Tier	4
This document is subject to controlled issue and can be found here: http://www.euromr.org/technical-requirements *** Uncontrolled if downloaded or printed ***		

The following information is specifically applicable to products relevant to this technical requirement and shall be included on the EU RO MR Type Approval Certificate:

- a) Approval conditions including limitations;
- b) Hardware, software, firmware name and version;
- c) Technical data according to IEC marking;
- d) Application and limitations.

6. APPROVAL DATE AND REVISION NUMBER

Date	Revision	Comment
2015-01-31	0.0	Accepted by EU RO MR Advisory Board
1 April 2016	0.1	CRF025 – Updated to new MR TR document format incl. par. 8; CRF026/026a – Witness testing & control of test specimen; CRF028 – addition of 6-month application clause.
1 July 2018	0.2	CRF032 / CRF035 - Revision of par. 2.b – Type testing requirements (Alignment of Electrical TRs) Corrected reference to standard IEC 60721-3-6 (1987) + A2 (1997)

7. BACKGROUND INFORMATION / REFERENCES

- a) EU RO Framework Document for the Mutual Recognition of Type Approval;
- b) IEC IEV 441-14-33;
- c) IEC 60947;
- d) SOLAS Ch. I, Reg. 3;
- e) IEC 60721-3-6 (1987) + A2 (1997);
- f) IEC 60092;
- g) ISO 9001;
- h) IMO Resolution A.813(19):1995;
- i) IEC 60533;
- j) IEC 60945;
- k) Environmental categories (see **Table 1**).

EU RO Mutual Recognition Technical Requirements

CONTACTORS WITH ELECTRONIC DEVICES	Version	0.2
	Adoption Date	1 July 2018
	Application Date	1 January 2019
	Tier	4
This document is subject to controlled issue and can be found here: http://www.euomr.org/technical-requirements *** Uncontrolled if downloaded or printed ***		

8. MAINTENANCE / CLARIFICATION OF TECHNICAL REQUIREMENTS

Anyone wishing to propose changes to this document or request clarification of technical issues should contact the EU RO MR Group Secretariat in the first instance: Secretariat@euomr.org.

Review and approval of change requests shall follow the EU RO MR Maintenance Process detailed in the EU RO Framework Document for the Mutual Recognition of Type Approval: <https://www.euomr.org/technical-requirements>.

TABLE 1 - ENVIRONMENTAL CATEGORIES

Environmental Category	Environmental Conditions						Test Conditions					
	Closed Area			Open Deck Area			Temperature		Climate			Vibrations
	Temperature	Relative Humidity	Vibrations	Temperature	Relative Humidity	Vibrations	Dry Heat	Cold	Temperature	Relative Humidity	Salt mist	
I	0°C to 45°C	up to 100%	0,7g				55°C	5°C	55°C	95%	-	0,7g
II	0°C to 45°C	up to 100%	4g				55°C	5°C	55°C	95%	-	4g
III	0°C to 55°C	up to 100%	0,7g				70°C	5°C	55°C	95%	-	0,7g
IV	0°C to 55°C	up to 100%	4g				70°C	5°C	55°C	95%	-	4g
EMC 1	IEC 60533 6.2.1											
EMC2	IEC 60533 6.2.2											

- END -