

# EU RO Mutual Recognition Technical Requirements

<b>ELECTRICAL/ELECTRONIC RELAYS</b>	Version	0.2
	Date	31 January 2015
	Tier	2
<b>*** Uncontrolled if downloaded or printed ***</b>		

1. PRODUCT DESCRIPTION .....	2
1.a General description of the product .....	2
1.b Application limitations .....	2
1.c Intended use .....	2
1.d System context .....	2
2. DESIGN EVALUATION.....	2
2.a Engineering evaluation requirements.....	2
2.b Type testing requirements .....	3
3. PRODUCTION REQUIREMENTS .....	4
4. MARKING REQUIREMENTS .....	4
5. TYPE APPROVAL CERTIFICATE CONTENT .....	4
6. APPROVAL DATE AND REVISION NUMBER .....	5
7. BACKGROUND INFORMATION / REFERENCES .....	5

## 1. PRODUCT DESCRIPTION

### 1.a General description of the product

#### Relays means:

- a) devices designed to produce sudden, predetermined changes in one or more electrical output circuits when certain conditions are fulfilled in the electrical input circuit controlling the device;
- b) thermal electrical relays which protect equipment from electrical thermal damage by the measurement of current flowing in the protection equipment;
- c) measuring relays (including time relays) and protection equipment including any combination of devices for power system protection such as control, monitoring and process interface equipment.

### 1.b Application limitations

- a) Restricted to LV relays according to IEC 60947-1 and IEC 60255 installed onboard ships with exceptions as per SOLAS Ch. I, Reg. 3;
- b) Installation on board ships within locations with climatic, biological, chemically active, mechanically active and mechanical environmental conditions not exceeding those for which performance has been proved according to IEC 60721-3-6 (1993) + A2 (1997);
- c) The requirements are not applicable for relays to be installed in areas where

# EU RO Mutual Recognition Technical Requirements

ELECTRICAL/ELECTRONIC RELAYS	Version	0.2
	Date	31 January 2015
	Tier	2
*** Uncontrolled if downloaded or printed ***		

explosive gases or vapor atmospheres may occur.

## 1.c *Intended use*

- a) Power supply system characteristics as per IEC 60092-101; 2.8;
- b) Environment category 6K4, 6B2, 6C2, 6S2 and 6M3 according to IEC 60721-3-6 or conditions specified in IEC 60947-1 Annex Q.

## 1.d *System context*

See 1.c

## 2. DESIGN EVALUATION

### 2.a *Engineering evaluation requirements*

#### 2.a.i. **Technical Requirements**

Type, ratings and characteristics of relays for intended applications shall be evaluated. In general, IEC 60947 and IEC 60255 series shall be observed.

#### 2.a.ii. **Technical documents to be submitted**

**IMPORTANT:** The English Language shall be used for all submitted documents.

#### **Prior to tests:**

- a) Proposed test program and test schedule;
- b) Description of test specimens and explanation of the selected test sample(s) providing evidence that the selected sample meets the most rigorous and demanding requirements;
- c) Product descriptions, manuals, data sheets, assembly drawings, dimension drawings, etc. clearly identifying the product;
- d) Complete accreditation certificate of the Test laboratory;
- e) Details of production sites;
- f) Product specification;
- g) Application, working area;
- h) Instructions on fitting, assembly and operation;
- i) QM-certificate according to ISO 9001 or equivalent by an accredited certifying body.

On completion of tests, a report shall be issued, identified by number and date, which

# EU RO Mutual Recognition Technical Requirements

<b>ELECTRICAL/ELECTRONIC RELAYS</b>	Version	0.2
	Date	31 January 2015
	Tier	2
<b>*** Uncontrolled if downloaded or printed ***</b>		

accurately, clearly and unambiguously presents the test results and all other relevant information.

Test report(s) shall include the following information:

- a) Type of product, with type number / serial number(s) and quantity tested;
- b) Test specification for the product identified by number, revision and date;
- c) Details of test equipment and measuring instruments stating serial numbers and calibration certificates;
- d) Names of the test engineer and the engineer approving the report;
- e) Ambient environmental conditions during the test;
- f) The test results with a description of any failures encountered;
- g) Conclusion.

Test report(s) shall be signed by the test personnel and verified by a EU RO or the agreed independent representative witnessing the tests.

The complete product test report(s) shall be submitted to the Type Approval Centre.

## **2.b Type testing requirements**

The following tests specified in IACS UR E10 or IEC 60947-1 shall be performed:

- a) Visual Inspection;
- b) Performance test (acc. to IEC 60947-1 or IEC 60255 and IEC 60947-6-2 for thermal relays);
- c) External power supply failure;
- d) Power supply variations;
- e) Dry heat;
- f) Damp heat;
- g) Vibration;
- h) Inclination;
- i) Insulation resistance;
- j) High Voltage;
- k) Cold;
- l) Flammability;
- m) Salt mist for relays installed on weather exposed areas. EMC tests are required in case of digital relays.

In cases where the tests are conducted at Nationally Accredited Laboratories, the presence of the EU RO surveyor may be omitted;

# EU RO Mutual Recognition Technical Requirements

<b>ELECTRICAL/ELECTRONIC RELAYS</b>	Version	0.2
	Date	31 January 2015
	Tier	2
<b>*** Uncontrolled if downloaded or printed ***</b>		

## 3. PRODUCTION REQUIREMENTS

### 3.a General requirements

Refer to EU RO "Product Quality Assurance (PQA)" procedure (Annex VI of EU RO Framework Document for the Mutual Recognition of Type Approval).

### 3.b Special requirements

Routine test according to relevant IEC 60947 series or IEC 60255 series.

- a) Production certification according to ISO 9001 or equivalent by an accredited certifying body;
- b) QM/QS audit (annual) to be submitted to the EU RO for review (similar to MED);
- c) Production of the equipment shall be limited to the facilities listed on EU RO certificate;
- d) Production and environmental requirements according to EU directives (for the consideration of the technical steering group);
- e) Changes to the product will invalidate the EU RO certification;
- f) RO. shall be granted access to all manufacturing and testing facilities, and provided with all the information necessary to perform its duties;
- g) General terms and conditions of EU RO shall be observed.

## 4. MARKING REQUIREMENTS

Manufacturers of the approved equipment are, in principle, to mark the product before shipment for identification of approved equipment as per referenced standard i.e. IEC 60947 item 5.2 or IEC 60255-1 item 6.1.

## 5. TYPE APPROVAL CERTIFICATE CONTENT

The EU RO MR Type Approval Certificate shall contain the minimum information as defined in the "EU RO Framework Document for the Mutual Recognition of Type Approval" - see Appendix I EU RO MR Type Approval Certificate Information.

The following information is specifically applicable to products relevant to this technical requirement and shall be included on the relevant EU RO MR Type Approval Certificate:

- a) Type designations and dimensions of enclosures/boxes;
- b) Product description;
- c) Environmental category (including additional tests where applicable);

# EU RO Mutual Recognition Technical Requirements

<b>ELECTRICAL/ELECTRONIC RELAYS</b>	Version	0.2
	Date	31 January 2015
	Tier	2
<b>*** Uncontrolled if downloaded or printed ***</b>		

d) Range of application.

## 6. APPROVAL DATE AND REVISION NUMBER

Date	Revision	Comment
2013-04-30	0.0	Accepted by Advisory Board
2014-01-31	0.1	CRF008 - Reference to EU RO Framework Document for the Mutual Recognition of Type Approval added.
2015-01-31	0.2	CRF018 – Revision to par. 2.a.ii - Technical documents to be submitted in English; CRF020 – Revision to par. 5 - 'Type Approval Certificate Content'

## 7. BACKGROUND INFORMATION / REFERENCES

- a) IEC 60947-1 Low-voltage switchgear and control gear - Part 1: General rules;
- b) IEC 60947 item 5.2;
- c) IEC 60255 series Measuring relays and protection equipment;
- d) IEC 60255-1 item 6.1;
- e) IACS UR E10 - "Test specification for Type Approval";
- f) EU RO Framework Document for the Mutual Recognition of Type Approval.

- END -