TEMPERATURE GAUGES AND TRANSMITTERS	Version	0.1
	Adoption Date	1 April 2016
	Application Date	1 October 2016
	Tier	4
This document is subject to controlled issue and can be found here: http://www.euromr.org/technical-requirements *** Uncontrolled if downloaded or printed ***		

1. PRODUCT DESCRIPTION	1
2. DESIGN EVALUATION	2
3. PRODUCTION REQUIREMENTS	3
4. MARKING REQUIREMENTS	3
5. TYPE APPROVAL CERTIFICATE CONTENT	4
6. APPROVAL DATE AND REVISION NUMBER	4
7. BACKGROUND INFORMATION / REFERENCES	4
8. MAINTENANCE / CLARIFICATION OF TECHNICAL REQUIREMENTS	5

1. PRODUCT DESCRIPTION

1.a General description of the product

Temperature gauges, temperature sensors and transmitters.

Gauges and sensors may be based on several working principles: bi-metallic (BM), liquid expansion (LE), gas-expansion (GE), thermo-resistors (RTD), thermocouples (TC), infrared (IR), etc.; the relevant features of which vary accordingly.

1.b Application limitations

When used for measurement of fluid temperature in piping systems or pressure vessels, thermometers, temperature transmitters or other temperature sensing devices shall be installed within thermowells so that the devices can be removed without impairing the integrity of the pressurized equipment.

1.c Intended use

Direct or indirect measurement of temperature (of fluids or solids, as applicable) in piping systems, pressure vessels, tanks, cargo holds, enclosed or open spaces, or machinery components.

1.d System context

Piping systems, pressure vessels, tanks, cargo holds, enclosed or open spaces, machinery components.

TEMPERATURE GAUGES AND TRANSMITTERS	Version	0.1
	Adoption Date	1 April 2016
	Application Date	1 October 2016
	Tier	4
This document is subject to controlled issue and can be found here: http://www.euromr.org/technical-requirements *** Uncontrolled if downloaded or printed ***		

2. DESIGN EVALUATION

2.a Engineering evaluation requirements

2.a i. Technical Requirements

- a) The materials of temperature gauges, sensors and transmitters, likely to come in to contact with the fluid whose temperature they are intended to measure, shall be compatible with the fluid itself;
- b) The minimum degree of protection, as applicable, shall be in accordance with the requirements set forth by the EU RO in charge of the vessel's classification, as a function of the intended location;
- c) Temperature gauges and sensors shall comply with a suitable recognized standard for such devices (e.g. IEC 584 for thermocouples; EN 13190 for GE, LE and BM thermometers; ASTM E 1137-97, ASTM E 644-98, IEC 751 and DIN 43760 for thermoresistors, etc.);
- d) Electrical and electronic temperature sensors and transmitters shall be in compliance with EU RO MR technical requirements for "SENSORS" (Tier 1). See par. 2.1.1 of the same for relevant technical requirements.

2.a.ii. Technical documents to be submitted

IMPORTANT: The English Language shall be used for all submitted documents;

- a) Technical specifications, data sheets, drawings, installation sheets and type test reports, describing the type and working principles of the temperature gauge or transmitter for which approval is requested, and showing compliance with the relevant technical requirements as per above point 2.a.i;
- b) Documents shall be submitted for electrical/electronic level sensor and transmitter: see the EU RO MR technical Requirement for "SENSORS" (Tier 1).

2.b Type testing requirements

a) Type tests shall be carried out as per selected suitable recognized standard;

TEMPERATURE GAUGES AND TRANSMITTERS	Version	0.1
	Adoption Date	1 April 2016
	Application Date	1 October 2016
	Tier	4
This document is subject to controlled issue and can be found here: http://www.euromr.org/technical-requirements *** Uncontrolled if downloaded or printed ***		

- b) For electrical/electronic temperature sensors (transmitters/transducers), type testing shall be carried out as per the EU RO MR technical requirement for "SENSORS" (Tier 1) par. 2.2.;
- c) Test specimens shall be taken from the production line or from stocks[†]. Tests shall be carried out in the presence of the EU RO Surveyor. In cases where the tests are conducted at Nationally Accredited Laboratories, the presence of an EU RO Surveyor may be omitted[†].
- † For further clarification of witnessing of tests and sampling the test specimen(s), refer to paragraphs 6, 7 and 8 of the EU RO "Design Evaluation Scheme" procedure (Appendix V of EU RO Framework Document for the Mutual Recognition of Type Approval found on

http://www.euromr.org/Guidance%20for%20Mutual%20Recognition)

3. PRODUCTION REQUIREMENTS

Refer to EU RO "Product Quality Assurance (PQA)" procedure (Appendix VI of EU RO Framework Document for the Mutual Recognition of Type Approval).

4. MARKING REQUIREMENTS

Manufacturers of the approved equipment are, in principle, to mark the product before shipment for identification of approved equipment as per referenced standard. In addition, and as a minimum, the following items to be marked at the suitable place:

- a) Manufacturer's name or equivalent;
- b) Type No. or symbol;
- c) Serial No. and date of manufacture;
- d) Particulars or ratings, including IP grade and class of accuracy.

TEMPERATURE GAUGES AND TRANSMITTERS	Version	0.1
	Adoption Date	1 April 2016
	Application Date	1 October 2016
	Tier	4
This document is subject to controlled issue and can be found here: http://www.euromr.org/technical-requirements *** Uncontrolled if downloaded or printed ***		

5. TYPE APPROVAL CERTIFICATE CONTENT

The EU RO MR Type Approval Certificate shall contain the minimum information as defined in the EU RO Framework Document for the Mutual Recognition of Type Approval - see Appendix I EU RO MR Type Approval Certificate Information.

The following information is specifically applicable to products relevant to this technical requirement and shall be included on the EU RO MR Type Approval Certificate:

- a) Environmental test items and test levels applied, if any;
- b) Approval conditions including limitations, if any;
- c) Hardware, firmware, software name and revision, if and as applicable.

6. APPROVAL DATE AND REVISION NUMBER

Date	Revision	Comment
2015-01-31	0.0	Accepted by EU RO MR Advisory Board
1 April 2016	0.1	CRF025 – Updated to new MR TR document format incl. par. 8; CRF026/026a – Witness testing & control of test specimen;
		CRF028 – addition of 6 month application clause.

7. BACKGROUND INFORMATION / REFERENCES

- a) EU RO Framework Document for the Mutual Recognition of Type Approval;
- b) IEC 584 for thermocouples;
- c) EN 13190 for GE, LE and BM thermometers;
- d) ASTM E 1137-97, ASTM E 644-98, IEC 751 and DIN 43760 for thermo-resistors, etc.;
- e) EU RO MR Technical Requirement for "SENSORS" (Tier 1).

TEMPERATURE GAUGES AND TRANSMITTERS	Version	0.1
	Adoption Date	1 April 2016
	Application Date	1 October 2016
	Tier	4
This document is subject to controlled issue and can be found here: http://www.euromr.org/technical-requirements *** Uncontrolled if downloaded or printed ***		

8. MAINTENANCE / CLARIFICATION OF TECHNICAL REQUIREMENTS

Anyone wishing to propose changes to this document or request clarification of technical issues should contact the EU RO MR Group Secretariat in the first instance: Secretariat@euromr.org.

Review and approval of change requests shall follow the EU RO MR Maintenance Process detailed in the EU RO Framework Document for the Mutual Recognition of Type Approval: http://www.euromr.org/Guidance%20for%20Mutual%20Recognition.

- END -